

إدارة توزيع الكهرباء Electricity Distribution Directorate

5340/6.910/1474/19/jb/190295 September 18th, 2019

FAX

Haji Ali Haji Co WLL,

Attn: Mr.Rajat Sahoo, Sales Manager.

Fax: 17275732

SUBJECT: EQUIPMENTS APPROVAL CABLE GLANDS MAKE:M/S BRASS COPPER & ALLOY (I) LTD.,(HEX), INDIA

Name of the Project: General

This has reference to the submittal received on 27th July 2019, along with documents for the subject item approval. We have reviewed the same in conjunction with previous submittals and decided to approve the following Cable glands from manufacturer M/s Brass Copper & Alloy(I) Ltd., (HEX), India:

- (i) BW Cable Gland(size16~63L)
- (ii) CW Cable Gland(size 16~63L)
- (iii)A2 Cable Gland(size 16~50L)

The above approval is subject to the following:-

- 1) The approval for the pertinent items is valid for five years only.
- 2) It is the responsibility of the local agent to ensure the standards and specifications of the above approved articles.
- 3) Any alteration or changes to the specifications of the above items will invalidate this approval.
- 4) This approval does not entitle the contractor to hold Electricity Distribution Directorate responsible in the event of non-performance of the item.

Note: For considering other types and higher sizes please submit the test reports for the same.

Regards,

Khalid Jassim Mohamed Sowayed

P.O. Box: 2, Tel: (+973) 17991999, Fax: (+973) 17728466

Chief, Engineering Services

JB/jb- ES(1654)

CC: 1) MAC Members-please see sharing folder ,(2) Abdulla Hameed & (3) File

www.ewa.bh

ص.ب: ۲ - هاتف: ۱۷۹۹۱۹۹۹ (۴۹۷۳) - فاکس: ۲۲ ۱۷۲۲۸ (۴۹۷۳)



إدارة توزيع الكهرباء Electricity Distribution Directorate

5340/6.910/1473/19/jb/190295 September 18th, 2019

FAX

Haji Ali Haji Co WLL,

Attn: Mr.Rajat Sahoo, Sales Manager.

Fax: 17275732

SUBJECT: EQUIPMENTS APPROVAL EARTH ROD & ACCESSORIES MAKE:M/S BRASS COPPER & ALLOY (I) LTD.,(HEX), INDIA

Name of the Project: General

This has reference to the submittal received on 27th July 2019, along with documents for the subject item approval. We have reviewed the same in conjunction with previous submittals and decided to approve the Earthing Grounding system using copper claded earh rod and accessories, from manufacturer M/s Brass Copper & Alloy(I) Ltd., (HEX), India.

The above approval is subject to the following:-

- 1) The approval for the pertinent items is valid for five years only.
- 2) It is the responsibility of the local agent to ensure the standards and specifications of the above approved articles.
- 3) Any alteration or changes to the specifications of the above items will invalidate this approval.
- 4) This approval does not entitle the contractor to hold Electricity Distribution Directorate responsible in the event of non-performance of the item.

Regards,

Khalid Jassim Mohamed Sowayed Chief, Engineering Services

JB/ib- ES(1654)

CC: 1) MAC Members-please see sharing folder ,(2) Abdulla Hameed & (3) File

www.ewa.bh

ص.ب: ۲ - هاتف: ۱۷۹۹۱۹۹۹ (۹۷۳) - فاکس: ۲۲ ۱۷۲۲۸ (۹۷۳)



إدارة توزيع الكهرباء Electricity Distribution Directorate

5340/6.910/[47\/19/jb/190295 September 18th, 2019

FAX

Haji Ali Haji Co WLL,

Attn: Mr.Rajat Sahoo, Sales Manager.

Fax: 17275732

SUBJECT: EQUIPMENTS APPROVAL CABLE LUGS & CLEATS MAKE:M/S BRASS COPPER & ALLOY (I) LTD.,(HEX), INDIA

Name of the Project: General

This has reference to the submittal received on 27th July 2019, along with documents for the subject item approval. We have reviewed the same in conjunction with previous submittals and decided to approve the following Tinned copper & aluminium cable lugs from manufacturer M/s Brass Copper & Alloy(I) Ltd., (HEX), India:

- a. Tinned copper cable lugs (HAHT) upto 150mmsq.
- b. Tinned aluminium cable lugs (Type A) upto 185mmsq.

The above approval is subject to the following:-

- 1) The approval for the pertinent items is valid for five years only.
- 2) It is the responsibility of the local agent to ensure the standards and specifications of the above approved articles.
- 3) Any alteration or changes to the specifications of the above items will invalidate this approval.
- 4) This approval does not entitle the contractor to hold Electricity Distribution Directorate responsible in the event of non-performance of the item.

Note: For considering other types and higher sizes please submit the test reports for the same.

Regards,

Khalid Jassim Mohamed Sowayed

Chief, Engineering Services

P.O. Box: 2, Tel: (+973) 17991999, Fax: (+973) 17728466

JB/jb- ES(1654)

CC. 1) MAC Members-please see sharing folder ,(2) Abdulla Hameed & (3) File

www.ewa.bh